



# Declaration of Conformity



# DECLARATION

**Applicant:** Victron Energy B.V.  
De Paal 35  
1351 JG Almere  
The Netherlands

**Product type:** Battery Inverter

**Model:** Phoenix Inverter 48/5000 230V VE.Bus

**Rating:** Input voltage: 38-66 Vdc;  
Input current: 118 Adc  
Output voltage: 225-235 Vac 50 Hz;  
Output current: 18.5 Aac;  
Output apparent power: 5000 VA;  
Output active power: 4000 W

A representative test sample of above stated model passed the tests according to:

**Standard:** IEC 62109-1:2010, EN 62109-1:2010  
IEC 60335-1:2010 (fifth Edition) +A1:2013  
EN 60335-1:2012 + A11:2014

**Report no:** 19PP350-01 and 19PP350-02

**Certificate no:** 20-018-01

**Date of issue:** 2020-04-02

**Kiwa Primara GmbH**  
Gewerbestraße 28  
87600 Kaufbeuren  
Germany  
Tel. +49 8341 99726-0  
info@primara.net  
www.kiwa.de

**Michael Schugg**

